

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Columbus, Ohio

Nº 146330

County Green Township Bath Section of Township Hamilton Plat
or Lot Number
Owner Charles & Rilda Willhoit Address 5 Dickey Avenue Fairborn, Ohio
Location of property 5 Dickey Avenue Fairborn, Ohio

CONSTRUCTION DETAILS

Casing diameter 5 5/8 Length of casing 112
Type of screen Length of screen
Type of pump Jet
Capacity of pump 480 Gal. P.H.
Depth of pump setting 108 Ft.

PUMPING TEST


Pumping rate 8 G.P.M. Duration of test 6 hrs.
Drawdown 0 ft. Date Feb. 12 1960
Developed capacity
Static level—depth to water 95 ft.
Pump installed by Earl Hollandsworth

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
Started in bottom of Cistern	0 Feet	7 Ft.
Sand & Gravel	7	50
Sand	50	74
Clay & Gravel	74	95
Clay Sand & Gravel & Water	95	105
Sand & Gravel	105	112

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm Earl Hollandsworth
Well Drilling
Address 5872 Shull Road Dayton 24, Ohio

Date February 12 1960
Signed

14
LOCATED