

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Columbus, Ohio

Nº 151526

County Summit Township Marton Section of Township
or Lot Number
Owner Leo Underwood Address R.D. #1, Barberton O.
Location of property 500 feet West of Sherman Cross Rd.

CONSTRUCTION DETAILS

Casing diameter 4" Length of casing 31-7"
Type of screen Length of screen
Type of pump
Capacity of pump
Depth of pump setting

PUMPING TEST


Pumping rate 4 G.P.M. Duration of test 1/2 hrs.
Drawdown 30 ft. Date May 20, 1953
Developed capacity 240 G.P.M.
Static level—depth to water 25 ft.
Pump installed by

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Clay.</u>	0 Feet	<u>28</u> Ft.
<u>Sand</u>	<u>28</u>	<u>40</u>
<u>Gray Shale</u>	<u>40</u>	<u>46</u>
<u>Sand</u>	<u>46</u>	<u>80</u>
<u>Brown Shale</u>	<u>80</u>	<u>95</u>
<u>Sand</u>	<u>95</u>	<u>100</u>
water at 60, 2 G.P.M., water at 102, 2 G.P.M.		

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm C. D. Seckman
Address Conal Fulton O.

Date May 20, 1953
Signed C. D. Seckman

RIDEY 2411

70