

STATE OF OHIO
OHIO WATER RESOURCES BOARD
DEPARTMENT OF PUBLIC WORKS
706 Ohio Depts. Bldg., Columbus, Ohio

Nº 15410

WELL LOG AND DRILLING REPORT

County MAHONING Township BOARDMAN Section of Township
or Lot Number.....
Owner L.A. BEEGHLY Address MARKET ST., YOUNGSTOWN, O.
Location of Property 1 MI. NORTH OF BOARDMAN, OHIO

CASING RECORD

Casing Diameter 10"
Length of Casing 179' 10"
Length of Screen ✓
Type of Screen ✓
Type of Pump ✓
Capacity of Pump ✓
Depth of Pump Setting ✓

PUMPING TEST


Date JULY 24, 1956
Developed Capacity 55 TO 90 GPM.
Duration of Test 8 Hrs.
Pumping Rate 90 G.P.M.
Drawdown 150 Ft.
Static Level of Completed Well 60 Ft.

WELL LOG

Formations	From	To
YELLOW CLAY SAND + GRAVEL	0 Feet	110 Ft.
BLUE CLAY (GUMBO)	110	150
FINE SAND	150	170
BROWN SAND + GRAVEL	170	175
GREY SANDY SHALE	175	190
" HARD ROCK	190	195
WHITE SANDSTONE	195	230
GREY SHALE	230	256
COAL	256	258
SHALE	258	280
HARD GRAY ROCK	280	282
GREY SHALE	282	300

MAP SHOWING LOCATION

Locate in reference to numbered
State Highways, St. intersections



See Reverse Side for Instructions

Drilling Firm T. G. McDONALD & SON Date JULY 30, 1956
Address CANFIELD, OHIO