

2007 700
397 700/V
Well drilled at
Fairview Trailer Park Mansfield Ohio

WELL LOG AND DRILLING REPORT

ORIGINAL

219 -160

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Columbus, Ohio

No 160704

County Richland Township Madison Section of Township 24
or Lot Number

Owner George Kuntov Address Canon Rd. Bedford, Ohio

Location of property On the North east corner of Bechtel & Walker ave.

CONSTRUCTION DETAILS

Casing diameter 4 1/4 Length of casing 129'
Type of screen none Length of screen —
Type of pump Submersible
Capacity of pump 15 gal per min
Depth of pump setting 110'

PUMPING TEST

Pumping rate 18 G.P.M. Duration of test 10 hrs.
Drawdown 5 ft. Date Oct. 10, 1955
Developed capacity —
Static level—depth to water 90' ft.
Pump installed by Driller


WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
Top Soil	0 Feet	1 Ft.
Yellow clay Sand & gravel	1'	28'
Blue " " "	28'	40'
Sand & gravel with clay	40'	63'
Yellow Sand Rock	63'	160'
White Sand Rock	160'	175'

Drilled 6" hole to
128' and set in 4 1/4
inch pipe to shut off
sand that contains much
the water

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm SALTZGABER DRILLING CO.
32 SO. ADAMS STREET
Address MANSEFIELD, OHIO

Date Oct. 28, 1955
Signed R. M. Saltzgaber

219-160