

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Columbus, Ohio

Nº 162796

County Dark Township Mississinewa Section of Township 18
Owner Jimmy A. Beam Address 127 SYCAMORE UNION CITY
Location of property on Wilson Road

CONSTRUCTION DETAILS

Casing diameter 4 Length of casing 265
Type of screen Length of screen
Type of pump Rida 3/4 HP
Capacity of pump 12 gal per min
Depth of pump setting 147 ft

PUMPING TEST

Pumping rate G.P.M. Duration of test hrs.
Drawdown ft. Date
Developed capacity
Static level—depth to water 110 ft.
Pump installed by Ben Pamme

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Yellow Clay</u>	<u>0 Feet</u>	<u>60 Ft.</u>
<u>Blue clay</u>	<u>60</u>	<u>138</u>
<u>gravel</u>	<u>138</u>	<u>160</u>
<u>Gravel</u>	<u>160</u>	<u>170</u>
<u>Hard Pan</u>	<u>170</u>	<u>210</u>
<u>Line</u>	<u>210</u>	<u>266</u>
	<u>266</u>	<u>320</u>

1085
266
819

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.

W.

E.

S.

See reverse side for instructions

Drilling Firm Ben Pamme
Address 44 Perry St

Date October 2 1966Signed Jimmy A. Beam

LOCATED

578