

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Columbus, Ohio

N^o 163574

County Green Township Beaver Creek Section of Township #1026
or Lot Number #1026

Owner B. P. Carter Address Shirlington PK Miamisburg Ohio

Location of property on corner Sunbeam ave and Grand Vista Dr
in Country Acres #7 lot #1026 4276-9

CONSTRUCTION DETAILS

Casing diameter 5 3/8 Length of casing 81
Type of screen none Length of screen none
Type of pump 1/2 HP jet, Stay Pite
Capacity of pump 480 gal HP
Depth of pump setting 75 ft

PUMPING TEST


Pumping rate 45 G.P.M. Duration of test 1 hrs.
Drawdown none ft. Date April 5-56
Developed capacity over 2500 gal HP
Static level—depth to water 40 ft.
Pump installed by D. J. Sullivan

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>clay</u>	0 Feet	<u>80</u> Ft.
<u>gravel water</u> <u>at 81 ft</u>	<u>80</u>	<u>81</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm David J. Sullivan
Address Woodland Hills Blvd
Dayton 4 Ohio

Date 4-5-56
Signed D. J. Sullivan

170