

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Columbus, Ohio

Nº 163576

County Mont Township Mad River Section of Township or Lot Number # 26

Owner Joe Dolinski Address Dayton RR#10

Location of property lot # 26 on Gary Dr in Northern circle
158 north off Needmore Rd, between St RTs 202 and 201

CONSTRUCTION DETAILS

PUMPING TEST

Casing diameter 5 5/8 Length of casing 79
Type of screen none Length of screen
Type of pump 1/2 HP Jet Stay Rite
Capacity of pump 500 gal
Depth of pump setting 70 ft


Pumping rate 30 G.P.M. Duration of test 2 hrs.
Drawdown none ft. Date 4-14-56
Developed capacity over 1800 gal HP
Static level—depth to water 59 ft.
Pump installed by D.J. Sullivan

WELL LOG

SKETCH SHOWING LOCATION

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>clay</u>	0 Feet	<u>26</u> Ft.
<u>Dry gravel</u>	<u>26</u>	<u>31</u>
<u>clay</u>	<u>31</u>	<u>76</u>
<u>gravel water</u>	<u>76</u>	<u>79</u>

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm

Date

Address

Signed

David J. Sullivan
4917 Woodland Hills Blvd
Dayton 4 Ohio

4-14-56
D.J. Sullivan

A