

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Columbus, Ohio

No 163580

Wood Haven Plat

County Green Township Beaumont Section of Township 112
or Lot Number #112

Owner Ray Jones Address Yenia RR#2

Location of property on Tralle Trail, second lot off Patterson Dr
from west of new ST RT #35 from Knollwood

CONSTRUCTION DETAILS

Casing diameter 5 5/8" Length of casing 39
Type of screen none Length of screen none
Type of pump 1/2 HP jet stay Rite
Capacity of pump 300 gph
Depth of pump setting 36 ft

PUMPING TEST

Pumping rate 27 G.P.M. Duration of test 1 hrs.
Drawdown 2 ft. Date June 27-56
Developed capacity 1600 gal hr
Static level—depth to water 12 ft.
Pump installed by D.F. Sullivan


WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>clay</u>	<u>0 Feet</u>	<u>38 Ft.</u>
<u>gravel</u>	<u>38</u>	<u>39</u>
<u>Water at 39'</u>		

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.

Drilling Firm David F. SullivanDate 6-27-56Address 4917 Woodland Hills BlvdSigned D.F. Sullivan

Dayton 4 Ohio