

WELL LOG AND DRILLING REPORT

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1500 Dublin Road
Columbus, Ohio

ORIGINAL



No. 183269

County KNOX Township JACKSON Section of Township

Owner EVERETT BECKLEY Address WALHONDING, O. RT. 1

Location of property S. R. 271 E. OF BLADENBURG TO CO. R. 38 TURN L
TO TWP. R. 178 1ST HOUSE ON L.

CONSTRUCTION DETAILS

Casing diameter 5 Length of casing 44
Type of screen Length of screen
Type of pump
Capacity of pump
Depth of pump setting
Date of completion

BAILING OR PUMPING TEST

BAIL Pumping rate 15 G.P.M. Duration of test 3 hrs.
Drawdown 16 ft. Date 6-9-58
Developed capacity 15 G.P.M.
Static level—depth to water 52 ft.
Pump installed by

WELL LOG

Formations
Sandstone, shale, limestone,
gravel and clay

From

To

CLAY & SAND
SHALE
CLAY
SAND ROCK
SHALE
WATER @ 80

0 Feet

12 Ft.

12

18

18

29

29


63

63

82

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm C. F. SHOEMAKER

Date 6-16-58

Address HANOVER O

Signed Carl F. Shoemaker

RT 1

3