

## WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio  
DEPARTMENT OF NATURAL RESOURCES  
Division of Water  
1500 Dublin Road  
Columbus, Ohio

F-F-1  
(Hickman Q)  
No. 183275

County LICKING Township FALLSBURY Section of Township

Owner <sup>Leitan</sup> LAYTON NELSON Address R.3 FRAZEYS BURG

Location of property N. ON RT. 79 APPROX. 14 MI. TO CO. RD. 226 THEN  
TO TWP. RD. 227 1ST HOUSE ON R. NEW HOUSE

## CONSTRUCTION DETAILS

## BAILING OR PUMPING TEST

Casing diameter 5" Length of casing 114

BAIL Pumping rate 10 G.P.M. Duration of test 2 hrs.

Type of screen Length of screen

Drawdown 5 ft. Date 8-20-62

Type of pump SUBMERGA

Developed capacity 10 G.P.M. +

Capacity of pump 600 G.P.H.

Static level—depth to water 165 ft.

Depth of pump setting 189

Pump installed by C.F. Shoemaker

Date of completion 8-22-62

## WELL LOG

## SKETCH SHOWING LOCATION

| Formations<br>Sandstone, shale, limestone,<br>gravel and clay | From   | To    |
|---------------------------------------------------------------|--------|-------|
| #3 TOP SOIL                                                   | 0 Feet | 2 Ft. |
| CLAY-SHALE                                                    | 3      | 35    |
| S. ROCK                                                       | 35     | 40    |
| GRAY SHALE                                                    | 40     | 105   |
| SAND ROCK                                                     | 105    | 110   |
| GRAY SHALE                                                    | 110    | 135   |
| BIG INJAN                                                     | 135    | 205   |

Locate in reference to numbered  
State Highways, St. Intersections, County roads, etc.

W.

NOTE!

35-40 - 3 GAL P.M. RED WATER

105-110 7 G.P.M.

BOTH VEINS RED WATER

CASED OFF

S.  
See reverse side for instructions

Drilling Firm SHOEMAKER DRILLING Date 8-25-62

Address NEWARK, O. RT. #7 Signed C.F. Shoemaker

