

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1500 Dublin Road
Columbus, Ohio

No. 186319

County FRANKLIN Township TRURO

PRESENT
TELEPHONE # CL-8-7067

Section of Township LOT # 4

Owner NORMAN PETERS

DRILLING ADDRESS: 2103 RODEBAUGH RD.
Address PRESENT ADDRESS: 156 Catta Ave, Cols. o.

Location of property (1 Mile S. State Rt. # 16 - 1 Mile North of Reynoldsburg - 500 Yds. E. Rt. # 605 Reynoldsburg, New Albany Rd.)

CONSTRUCTION DETAILS

Casing diameter 8" Length of casing 84'
Type of screen NONE Length of screen ---
Type of pump *
Capacity of pump *
Depth of pump setting Suggested 50'
Date of completion *

BAILING OR PUMPING TEST

Pumping rate 12 G.P.M. Duration of test 3 hrs.
Drawdown 30 ft. Date 4-28-57
Developed capacity Min. 12 G.P.M.
Static level—depth to water 19.5 ft.
Pump installed by *

WELL LOG

Formations
Sandstone, shale, limestone,
gravel and clay

From

To

Fill Dirt	0 Feet	2 Ft.
Top Soil	2 "	5 "
Brown Clay & Gravel	5 "	18 "
Gray Clay & Gravel	18 "	31 "
Gray Clay (Only)	31 "	41 "
Quick Sand	41 "	80 "
Sand & Gravel	80 "	85 "

WATER @ 41' thru 80' in
QUICK SAND. (Unable to determine amount
because of heaving of sand.)

USEABLE WATER @ 84'


NO PERFORATION:

DRIVE SHOE ON BTM. JOINT.

* PUMP NOT PURCHASED AT DATE
OF DRILLING COMPLETION.

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



S.

See reverse side for instructions

Drilling Firm Mullet & Swingle Drilling Co.

Address 3325 Dale Ave., Columbus 13, Ohio

Date 29th April 1957

Signed [Signature]