

Page 1 of 1 for this record.

WELL LOCATION	CONSTRUCTION DETAILS																														
County <u>WOOD</u> Township <u>WEBSTER</u>	Drilling Method: <u>AIR HAMMER</u>																														
Owner/Builder <u>BRYAN HARDY</u>	BOREHOLE/CASING (Measured from ground surface)																														
Address of Well Location <u>20601 CARIS RD</u>	1 { Borehole Diameter <u>10</u> inches Depth <u>28</u> ft. Casing Diameter <u>6</u> in. Length <u>30</u> ft. Thickness <u>0.188</u> in.																														
City <u>BOWLING GREEN</u> Zip Code +4 <u>43402</u>	2 { Borehole Diameter <u>5.5</u> inches Depth <u>125</u> ft. Casing Diameter <u>6</u> in. Length <u>30</u> ft. Thickness <u>0.188</u> in.																														
Permit No. <u>382742</u> Section; _____ and/or Lot No. _____	Casing Height Above Ground <u>2</u> ft.																														
Use of Well <u>DOMESTIC</u>	Type { 1: <u>Galvanized</u> 2: <u>Galvanized</u>																														
Coordinates of Well (Use only one of the below coordinate systems)	Joints { 1: <u>Welded</u> 2: <u>Welded</u>																														
<u>State Plane Coordinates</u>	SCREEN																														
N ☐ X _____ +/- _____ ft.	Diameter _____ in. Slot Size _____ in. Screen Length _____ ft.																														
S ☐ Y _____ +/- _____ ft.	Type _____ Material _____																														
<u>Latitude, Longitude Coordinates</u>	Set Between _____ ft. and _____ ft.																														
Latitude: <u>41.435</u> Longitude: <u>83.484722</u>	GRAVEL PACK (Filter Pack)																														
Elevation of Well in feet: _____ +/- _____ ft.	Material/Size _____ Vol/Wt. Used _____																														
Datum Plane: ☐ NAD27 ☐ NAD83 Elevation Source _____	Method of Installation _____																														
Source of Coordinates: <u>GPS</u>	Depth: Placed From: _____ ft. To: _____ ft.																														
Well location written description: <u>100 FT FROM NW CORNER OF HOUSE</u>	GROUT																														
	Material <u>Bentonite slurry</u> Vol/Wt. Used <u>90 gal</u>																														
	Method of Installation <u>Pumped w/Tremie pipe</u>																														
	Depth: Placed From: <u>0</u> ft. To: <u>28</u> ft.																														
Comments on water quality/quantity and well construction: <u>CLEAR AND ODERLESS</u>	DRILLING LOG*																														
	FORMATIONS INCLUDE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.																														
	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Color</th> <th>Texture</th> <th>Formation</th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td>TAN</td> <td>DRY</td> <td>CLAY</td> <td>0</td> <td>21</td> </tr> <tr> <td>DARK GRAY</td> <td>HARD</td> <td>HARDPAN</td> <td>21</td> <td>23</td> </tr> <tr> <td>LT. GRAY</td> <td>BROKEN</td> <td>LIMESTONE</td> <td>23</td> <td>24</td> </tr> <tr> <td>LT. GRAY</td> <td>SOLID</td> <td>LIMESTONE</td> <td>24</td> <td>125</td> </tr> <tr> <td colspan="3" style="text-align: right;">Water Encountered At</td> <td>105</td> <td>125</td> </tr> </tbody> </table>	Color	Texture	Formation	From	To	TAN	DRY	CLAY	0	21	DARK GRAY	HARD	HARDPAN	21	23	LT. GRAY	BROKEN	LIMESTONE	23	24	LT. GRAY	SOLID	LIMESTONE	24	125	Water Encountered At			105	125
Color	Texture	Formation	From	To																											
TAN	DRY	CLAY	0	21																											
DARK GRAY	HARD	HARDPAN	21	23																											
LT. GRAY	BROKEN	LIMESTONE	23	24																											
LT. GRAY	SOLID	LIMESTONE	24	125																											
Water Encountered At			105	125																											
WELL TEST *																															
Pre-Pumping Static Level <u>16</u> ft. Date <u>9/18/2007</u>																															
Measured from <u>TOP OF CASING</u>																															
Pumping test method <u>AIR</u>																															
Test Rate <u>25</u> gpm Duration of Test <u>0.5</u> hrs.																															
Feet of Drawdown <u>109</u> ft. Sustainable Yield <u>25</u> gpm																															
*(Attach a copy of the pumping test record, per section 1521.05, ORC)																															
Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No																															
PUMP/PITLESS																															
Type of pump _____ Capacity _____ gpm																															
Pump set at _____ ft. Pitless Type _____																															
Pump installed by <u>N/A - NO PUMP, WELL ONLY</u>																															
I hereby certify the information given is accurate and correct to the best of my knowledge.																															
Drilling Firm <u>COX DRILLING, llc</u>																															
Address <u>1213 CALDWELL RD</u>																															
City, State, Zip <u>BRADNER OH 43406</u>																															
Signed <u>ROBERT COX</u> Date <u>10/11/2007</u>																															
(Filed Electronically)																															
ODH Registration Number <u>02941</u>	Aquifer Type (Formation producing the most water.) <u>LIMESTONE</u>																														
	Date of Well Completion <u>9/18/2007</u> Total Depth of Well <u>125</u> ft.																														

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
Distribute copies of this record to Customer, and Local Health Department.