

WELL LOG AND DRILLING REPORT

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1500 Dublin Road
Columbus, Ohio

No. 203736

County Franklin Township Putnam Section of Township 3
Owner George L. Starnes Address R#1 Coldwater Ohio
Location of property 1 1/2 mi. S. on R. 218 West 74 1/2 mi. S. on R. 218 House on south side

CONSTRUCTION DETAILS

Casing diameter 4 1/4 Length of casing 41'
Type of screen 1/2" mesh Length of screen 12'
Type of pump Rapiday 1/2 HP
Capacity of pump 350 per hour
Depth of pump setting 50'
Date of completion 11/6/65

BAILING OR PUMPING TEST

Pumping rate 5 G.P.M. Duration of test 3 hrs.
Drawdown 10 ft. Date 11/6/65
Developed capacity 311 G.P.M.
Static level—depth to water 35' ft.
Pump installed by R. W. Andrew
Coldwater Ohio

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>0</u>	<u>0 Feet</u>	<u>10</u> Ft.
<u>10</u>	<u>10</u>	<u>30</u>
<u>Hard sand</u>	<u>30</u>	<u>41</u>
<u>103 1/2</u>	<u>41</u>	<u>103 1/2</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

