

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCESDivision of Water
1500 Dublin Road
Columbus, Ohio

No. 210162

County Montgomery Township ~~Franklin~~ Moraine Section of Township
 Owner Frigidairi Dev. Inc. Address Dayton, Ohio
 Location of property Well # 30 - Moraine Plant

CONSTRUCTION DETAILS

Casing diameter 20" Length of casing 148'
 Type of screen Red Brass Length of screen 30'
 Type of pump
 Capacity of pump
 Depth of pump setting
 Date of completion

BAILING OR PUMPING TEST

Pumping rate 1000 G.P.M. Duration of test 1/2 hrs.
 Drawdown 4 1/2' ft. Date 11/7/59
 Developed capacity 1000 GPM
 Static level—depth to water 32' ft.
 Pump installed by

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Fill</u>	<u>0 Feet</u>	<u>10 Ft.</u>
<u>gravel</u>	<u>10</u>	<u>36</u>
<u>Till</u>	<u>36</u>	<u>73</u>
<u>Till - Little gravel</u>	<u>73</u>	<u>86</u>
<u>Gravel & Sandy Till</u>	<u>86</u>	<u>120</u>
<u>Till</u>	<u>120</u>	<u>128</u>
<u>gravel</u>	<u>128</u>	<u>150</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.

Well # 30

Moraine Plant
Frigidairi Dev.
Inc.
Dayton, Ohio

W.

E.

S.

See reverse side for instructions

Drilling Firm Don Roe
 Address Vandalia, Ohio

Date 11/7/59
 Signed Don Roe

C62