

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1500 Dublin Road
Columbus, Ohio

No. 212709

County Butler Township St. Clair Section of Township lots 106-107
Owner Herbert Homan Address 2069 St. Clair St.
Location of property St. Clair St. Williamsdale, Ohio West side

CONSTRUCTION DETAILS

Casing diameter 4" Length of casing 32'
Type of screen none Length of screen —
Type of pump —
Capacity of pump —
Depth of pump setting —
Date of completion 9-14-61

BAILING OR PUMPING TEST


Pumping rate 10 G.P.M. Duration of test 4 hrs.
Drawdown 1' ft. Date 9-14-61
Developed capacity 600 gal. per hr.
Static level—depth to water 25' ft.
Pump installed by —

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Top soil</u>	0 Feet	<u>4'</u> Ft.
<u>gravel</u>	<u>4'</u>	<u>20'</u>
<u>clay</u>	<u>20'</u>	<u>25'</u>
<u>sand & gravel</u>	<u>25'</u>	<u>32'</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm Zappert Pump Repair & Well Drilling Date 9-15-61
Address 903 Somerville Jacksonburg Rd. Signed Stewart H. Zappert
Somerville, Ohio

H
LOCATED