

WELL LOG AND DRILLING REPORT

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1500 Dublin Road
Columbus, Ohio

ORIGINAL

NL 15

No. 213307

County DELAWARE Township DEL. O Section of Township

Owner DON DEVAULT Address 177 N. WASHINGTON ST

Location of property 1 1/2 W. OF DEL. ROUTE 36

CONSTRUCTION DETAILS

Casing diameter 4" Length of casing 40'
Type of screen Length of screen
Type of pump
Capacity of pump
Depth of pump setting
Date of completion

BAILING OR PUMPING TEST

Pumping rate 14 G.P.M. Duration of test 2 hrs.
Drawdown 20 ft. Date 6-27-59
Developed capacity 7 G.P.M.
Static level—depth to water 30 ft.
Pump installed by


WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
CLAY	0 Feet	15 Ft.
GRAVEL	15	39
LIMESTONE	39	63

WATER AT 40'

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm NORBERT HUDSON

Date 6-27-59

Address MARYSVILLE O. RR #3

Signed N. Hudson

14

14