

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1500 Dublin Road
Columbus, Ohio

No. 213728

County JEFFERSON Township CROSS CREEK Section of Township 5 EC. 5

Owner ANTHONY TERMANA, JR. Address _____

Location of property COUNTY ROAD 77

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

Casing diameter 8 1/4" Length of casing 40'
Type of screen _____ Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion _____

Pumping rate _____ G.P.M. Duration of test _____ hrs.
Drawdown NONE ft. Date 9-13-61
Developed capacity _____
Static level—depth to water 35 ft.
Pump installed by _____

WELL LOG

SKETCH SHOWING LOCATION

Formations
Sandstone, shale, limestone,
gravel and clay

From

To

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.


LOAM	0 Feet	20 Ft.
SAND & GRAVEL	20	23
RED CLAY	23	38
SANDSTONE	38	45
GRAY SHALE	45	56

WATER AT 50'

N.

W.

E.



S.

See reverse side for instructions

Drilling Firm JAMES STEWART

Date 10-4-61

Address ST. RT. 7, TORONTO, O.

Signed James Stewart

(COSTONIA)

118