

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1500 Dublin Road
Columbus, Ohio

No. 214576

County Franklin Township Yanick Section of Township
Owner H. M. Binnell Address 6291 Renner Road
Location of property 6345 Renner Rd. 1/3 mi East of Altan
County Road

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

Casing diameter 4 1/4" Length of casing 81 ft Pumping rate 10 G.P.M. Duration of test 1 1/2 hrs.
Type of screen None Length of screen Drawdown None ft. Date Aug 3, 1964
Type of pump Developed capacity 600 G.P.H.
Capacity of pump Static level—depth to water 30 ft ft.
Depth of pump setting Pump installed by
Date of completion

WELL LOG

SKETCH SHOWING LOCATION

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Yellow clay</u>	<u>0 Feet</u>	<u>12 Ft.</u>
<u>Blue sandy "</u>	<u>12</u>	<u>60</u>
<u>Sand</u>	<u>60</u>	<u>81</u>
<u>Limestone</u>	<u>81</u>	<u>87</u>

First Water at
82 ft. More at
85 "

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

6345 Renner Rd

Renner Rd.
Renner Road 1/3 mi. E. Well.

Altan County Rd.

See reverse side for instructions

Drilling Firm M. S. Boster
Address 419 Stoddant ave.
Columbus, Ohio

Date August 4, 1964
Signed M. S. Boster