

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1500 Dublin Road
Columbus, Ohio

No. 222222

County KNOX Township MILFORD Section of Township SOUTH
Owner WILLIAM B. WATSON, JR. Address RT #2 Centerburg, Ohio
Location of property on County Road

CONSTRUCTION DETAILS

Casing diameter 5 1/2 Length of casing 29'
Type of screen NONE Length of screen
Type of pump
Capacity of pump
Depth of pump setting 21'
Date of completion 7, 1, 63

BAILING OR PUMPING TEST

Pumping rate 10 G.P.M. Duration of test 4 hrs.
Drawdown 6 ft. Date 7, 1, 63
Developed capacity 10 G.P.M.
Static level—depth to water 14 ft.
Pump installed by OWNER

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>YELLOW CLAY</u>	<u>0 Feet</u>	<u>18 Ft.</u>
<u>BLUE CLAY</u>	<u>18</u>	<u>28</u>
<u>WATER & GRAVEL</u>	<u>28</u>	<u>29</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

