

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1500 Dublin Road
Columbus, Ohio

No. 223550

County Fairfield Township Madison Section of Township 19
Owner Miles Hissner Address Amanda #2
Location of property Dunke

CONSTRUCTION DETAILS

Casing diameter 4 Length of casing 7'
Type of screen ✓ Length of screen ✓
Type of pump Jet
Capacity of pump 1
Depth of pump setting 90
Date of completion

BAILING OR PUMPING TEST


Pumping rate G.P.M. Duration of test 3 hrs.
Drawdown 10 ft. Date Nov. 24-64
Developed capacity 5 gal
Static level—depth to water 60 ft.
Pump installed by Mat Thomas

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
	0 Feet	Ft.
<u>Yellow clay</u>	<u>40-0</u>	<u>40-0</u>
<u>Blue "</u>	<u>5-0</u>	<u>45-0</u>
<u>Yellow "</u>	<u>22-0</u>	<u>67-0</u>
<u>Red sand rock</u>	<u>13-0</u>	<u>80-0</u>
<u>Yellow rock</u>	<u>65-0</u>	<u>145-0</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm Thomas
Address Amanda #2

Date
Signed Blair Kershner

