

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1500 Dublin Road
Columbus, Ohio

No. 224311

County Mahoning Township Goshen Section of Township _____
Owner Kenneth McNeil Address R.D. 4 Salem Ohio
Location of property Call Road

CONSTRUCTION DETAILS

Casing diameter 6 5/8 Length of casing 73
Type of screen _____ Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion _____

BAILING OR PUMPING TEST


Pumping rate 15 G.P.M. Duration of test _____ hrs.
Drawdown 30 ft. Date _____
Developed capacity 15
Static level—depth to water 20 ft.
Pump installed by _____

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Clay gravel</u> <u>shale</u>	0 Feet <u>73</u>	<u>73</u> Ft. <u>83</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



Drilling Firm E. H. Weingart
Address R.D. 4 Salem Ohio

Date Aug 28 - 61
Signed E. H. Weingart