

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1500 Dublin Road
Columbus, Ohio

No. 224743

County Portage Township Randolph Section of Township _____
Owner Robert White Address 1170 Alway
Location of property 1/2 mile South of Waterloo Rd

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

Casing diameter 4 Length of casing 105
Type of screen drive Length of screen 3'
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion _____

Pumping rate 5 1/2 G.P.M. Duration of test 1/2 hrs.
Drawdown 35 ft. Date 8-18-65
Developed capacity _____
Static level—depth to water 55 ft.
Pump installed by _____

WELL LOG

SKETCH SHOWING LOCATION

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>yellow clay</u>	0 Feet	<u>24</u> Ft.
<u>" Sand</u>	<u>24</u>	<u>38</u>
<u>gray "</u>	<u>38</u>	<u>67</u>
<u>quick Sand</u>	<u>67</u>	<u>102</u>
<u>gray "</u>	<u>102</u>	<u>105</u>

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.
W. Waterloo Rd E.
a
B
P
A
g
R
d
S.

See reverse side for instructions

Drilling Firm Brych's & sons pump & drill serv Date 8-18-65
Address 915 Hunt St Signed Leroy C. Brych
Akron 6 O

LOCATED
2/8