

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER.
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES

Division of Water
1562 W. First Avenue
Columbus, Ohio

JK (133)
No. 236436

County Fairfield Township Pleasant Section of Township
Owner Hugh W Bay Address Pleasantville RK 1
Location of property

CONSTRUCTION DETAILS

Casing diameter 5 5/8 Length of casing 28
Type of screen Length of screen
Type of pump
Capacity of pump
Depth of pump setting
Date of completion May 22, 1960

BAILING OR PUMPING TEST


BAIL
Pumping rate 12 G.P.M. Duration of test 4 hrs.
Drawdown 3 ft. Date May 22, 1960
Developed capacity 20 GPM
Static level—depth to water 42 ft.
Pump installed by

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From 0 Feet	To Ft.
Clay & Gravel	0	16
Red Sandstone	16	37
Gray Sandstone	37	60
Water @ 48 57		

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



Drilling Firm Joe Christy
Address Amherst, OH

Date May 22, 1960
Signed Joe Christy