

WELL LOG AND DRILLING REPORT

State of Ohio

PLEASE USE PENCIL
OR TYPEWRITER.
DO NOT USE INK.

DEPARTMENT OF NATURAL RESOURCES

Division of Water
1562 W. First Avenue
Columbus, Ohio

No. 241549

County Lucas Township Dover Section of TownshipOwner C. I. Hatcher Address Dover, Ohio R.D. 2Location of property 2 mi. South of Strasburg - St. Rt. 21-250

CONSTRUCTION DETAILS

BAILING TEST

Casing diameter 5" Length of casing 200 1/2' Pumping rate 30 G.P.M. Duration of test hrs.

Type of screen bar screen Length of screen Drawdown 66 ft. Date

Type of pump Developed capacity

Capacity of pump Static level—depth to water 29 ft.

Depth of pump setting Pump installed by


Date of completion 12-27-61

WELL LOG

SKETCH SHOWING LOCATION

Formations Sandstone, shale, limestone, gravel and clay	From	To
Washed Formation	0 Feet	42 Ft.
Dark Shale	42 ft.	78 ft.
Sandstone	78 ft.	142 ft.
Dark Shale	142 ft.	166 ft.
Sandstone	166 ft.	169 ft.
Light Shale	169 ft.	175 ft.
Dark Shale	175 ft.	186 ft.
Coal	186 ft.	188 ft.
Clay	188 ft.	193 ft.
Sandy clay	193 ft.	198 ft.
Dark Shale	198 ft.	228 ft.
Sandstone	228 ft.	245 ft.

Made water at 228 and 235

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.Drilling Firm Marion Harvey Co. Date March 20, 1961Address 128 6th St. S.W. Strasburg, Ohio Signed Ethan Harvey