

PLEASE USE PENCIL
OR TYPEWRITER.
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio

No. 247986

County Licking Township Washington Section of Township N.E.
Owner The Delux Ice Cream Co Address Utica
Location of property 1 mile south of Utica on Rt. 13

CONSTRUCTION DETAILS

Casing diameter 10" Length of casing 110'
Type of screen COOK STRAINER Length of screen 10'
Type of pump D.W. TURBINE
Capacity of pump 200 G.P.M.
Depth of pump setting 85'
Date of completion June 20, 1961

BAILING OR PUMPING TEST


Pumping rate 200 G.P.M. Duration of test 7.2 hrs.
Drawdown 2 ft. Date June 20, 1961
Developed capacity 200 G.P.M.
Static level—depth to water 22 ft.
Pump installed by Scapple

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
	0 Feet	 Ft.
<u>Brown clay & gravel</u>	<u>0'</u>	<u>51'</u>
<u>Water gravel</u>	<u>51'</u>	<u>120'</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

GLENN C. APPLGATE
WATER WELL DRILLING
Drilling Firm 131 W. Orchard St.
Address NEWARK, OHIO

Date June 30, 1961
Signed Glenn C. Applegate

(456)