

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio

PLEASE USE PENCIL
OR TYPEWRITER.
DO NOT USE INK.

DEPARTMENT OF NATURAL RESOURCES

Division of Water
1562 W. First Avenue
Columbus, Ohio

No. 249266

County Belmont Township Warren Section of Township 30
 Owner Jimenez Carpenter Address Barleys Mills
 Location of property 1/2 mi east of Barleys Mills

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST


Casing diameter 6 Length of casing 67 ft Pumping rate 2 G.P.M. Duration of test 6 hrs.
 Type of screen Length of screen Drawdown ft. Date Sept 22, 1961
 Type of pump Developed capacity
 Capacity of pump Static level—depth to water 40 ft.
 Depth of pump setting Pump installed by
 Date of completion Sept 22, 1961

WELL LOG

SKETCH SHOWING LOCATION

Formations Sandstone, shale, limestone, gravel and clay	From	To
	0 Feet	18 Ft.
<u>yellow shale</u>		
<u>red shale</u>	<u>18</u>	<u>40</u>
<u>pink shale</u>	<u>40</u>	<u>67</u>
<u>water at 40 ft</u>		

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm Glenn E. Warrick
307 N. Riverside Ave
 Address Barnesville, Ga

Date Sept 22, 1961
 Signed Glenn E Warrick

CR 120

38