

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER.
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio

No. 252622

County FRANKLIN Township PERRY Section of Township _____
Owner PAUL O. SCHUMAN Address 4740 BRIGHT RD. DUBLIN, O.
Location of property SAME

CONSTRUCTION DETAILS

Casing diameter 4 1/4" Length of casing 30'
Type of screen _____ Length of screen _____
Type of pump Rapdayton Model #52D48
Capacity of pump 900 G.P.H.
Depth of pump setting 90'
Date of completion Nov. 10th 1961

BAILING OR PUMPING TEST

Pumping rate 10 G.P.M. Duration of test 12 hrs.
Drawdown None ft. Date Nov. 10th 1961
Developed capacity Unknown
Static level—depth to water 70 ft.
Pump installed by Sells-Suburban Well & Water Supply Dublin TU91355

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
CLAY	0 Feet	4 Ft.
LIMESTONE	4	105

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

W.	N. B h t e r s i d e D r R o u t e 2 5 7 S.	Bright Road XXXXXXXXXXXXXXXXXXXX State Route #161
----	---	--

See reverse side for instructions

Drilling Firm Sells-Suburban Well & Water Supply Date Nov. 10th 1961
Address Dublin, Ohio Signed Robert L. Sells