

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER.
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio

No. 252623

County FRANKLIN Township PERRY Section of Township _____

Owner W.P. ANAWALT Address 5623 GODOWN ROAD COLS. 21, 0.

Location of property SAME

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

Casing diameter 4 1/4" Length of casing 80'
Type of screen None Length of screen _____
Type of pump Fairbanks Morse Jet 1 H.P.
Capacity of pump 10 G.P.M.
Depth of pump setting 60'
Date of completion Dec. 2nd, 1961

Pumping rate 10 G.P.M. Duration of test 12 hrs.
Drawdown None ft. Date Nov. 2nd, 1961
Developed capacity 10 G.P.M.
Static level—depth to water 50 ft.
Pump installed by Sells-Suburban Well & Water

WELL LOG

SKETCH SHOWING LOCATION

Formations Sandstone, shale, limestone, gravel and clay	From	To
CLAY	0 Feet	56 Ft.
Sand & Clay	56	64
Sand	64	78
Gravel	78	80

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

W. Godown Rd

N.
L
i
n
w
o
r
t
h

R
o
a
d

S.

E.

See reverse side for instructions

Drilling Firm Sells-Suburban Well & Water Sup Date Nov. 2nd, 1961

Address Dublin, Ohio TU 91355 Signed Robert L. Sells

455