WELL LOG AND DR..

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio

PLEASE USE PENCIL OR TYPEWRITER. DO NOT USE INK.

No. 255428
126

County FRANKLIN Township ~~JACKSON~~ Pleasant Section of Township

Owner CLIFTY LAYWELL Address 6702 DARBY BLVD

Location of property DARBY DALE CORP

CONSTRUCTION DETAILS

Casing diameter 4 1/2 OD Length of casing 65

Type of screen NONE Length of screen

Type of pump 1/2 H.P. JET

Capacity of pump 450 GPH

Depth of pump setting 58

Date of completion 4-1-61

BAILING OR PUMPING TEST

Pumping rate 8 G.P.M. Duration of test 1 hrs.

Drawdown N ft. Date 4-1-61

Developed capacity

Static level—depth to water 50 ft.

Pump installed by G. F. Ryan

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
CLAY	0 Feet	31 Ft.
SAND	31	33
CLAY	33	50
SANDY GRAVEL	50	65

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm G. F. Ryan Well Drilling Date 4-1-61

Address 4371 ORCHARD LANE OBETZ Signed G. F. Ryan