

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio

PLEASE USE PENCIL
OR TYPEWRITER.
DO NOT USE INK.

DEPARTMENT OF NATURAL RESOURCES

Division of Water
1562 W. First Avenue
Columbus, Ohio

No. 258889

County Hamilton Township Crosby Section of Township North
 Owner NATIONAL Lead Co. of Ohio Address Box 39158 Cinti. Ohio
Zone 39
 Location of property S.R. 128 Fernald Ohio

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST


Casing diameter 8" Length of casing 85' Pumping rate 380 G.P.M. Duration of test 24 hrs.
 Type of screen Red BRASS Length of screen 30' Drawdown ft. Date
 Type of pump Vertical Turbine Developed capacity
 Capacity of pump 200 G.P.M. Static level—depth to water ft.
 Depth of pump setting 79' 4" Pump installed by Hyden Bros Drilling Co
 Date of completion 9/27/63

WELL LOG

SKETCH SHOWING LOCATION

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>clay + sand</u>	<u>0 Feet</u>	<u>40 Ft.</u>
<u>sand + gravel</u>	<u>40'</u>	<u>105'</u>

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm Hyden Bros Drilling Co
 Address 6105 Wooster Rd.

Date 9/27/63
 Signed Ralph W. Hyden

130