

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio

PLEASE USE PENCIL
OR TYPEWRITER.
DO NOT USE INK.

DEPARTMENT OF NATURAL RESOURCES

Division of Water
1562 W. First Avenue
Columbus, Ohio

No. 260177

County Portage Township Pavonia Section of TownshipOwner Dan Cross Address PavoniaLocation of property Patience Lane south of HRT Co.

CONSTRUCTION DETAILS

Casing diameter 4 Length of casing 72Type of screen Warp Length of screen 3Type of pump Warp

Capacity of pump

Depth of pump setting 72

Date of completion

BAILING OR PUMPING TEST

Pumping rate.....G.P.M. Duration of test.....hrs.


Drawdown.....ft. Date May 12 1961Developed capacity 4 gals/minStatic level—depth to water 21 ft

Pump installed by

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
	0 Feet	27 Ft.
Clay.		
Sand Clay	27	45
Sand,	45	51
Clay Sand,	51	64
Sand.	64	68
Sand Gravel,	68	72

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

See reverse side for instructions

Drilling Firm Carl F. PattersonAddress 57 Strong Rd.Date May 13 1961Signed Carl F. Patterson323
LOCATED