

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER.
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio

67
No. 263996

County Sevier Township Summit Section of Township 5
Owner Mr. Clyde Beck N of B & 1/4 Address London St Summit
Location of property 1/4 on Co 110 off of SR 37 on the left side

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

Casing diameter 5 Length of casing 80
Type of screen Length of screen
Type of pump
Capacity of pump
Depth of pump setting
Date of completion July 21, 1966

Pumping rate 8 G.P.M. Duration of test 1 hrs.
Drawdown 15 ft. Date July 21, 1966
Developed capacity 10
Static level—depth to water 65 ft.
Pump installed by


WELL LOG

SKETCH SHOWING LOCATION

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>clay</u>	<u>0 Feet</u>	<u>80 Ft.</u>
<u>Rock</u>	<u>80</u>	<u>106</u>
<u>water at</u>	<u>80</u>	

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.



S.

See reverse side for instructions

Drilling Firm Robert & Son
Address Box 125 Jackson

Date July 21, 1966
Signed Robert & Son

