

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio

PLEASE USE PENCIL
OR TYPEWRITER.
DO NOT USE INK.

DEPARTMENT OF NATURAL RESOURCES

Division of Water
1562 W. First Avenue
Columbus, Ohio

No. 269590

County Stark Township Trimishell Section of Township 20Owner Elmer Seymour Address -Location of property 6858 Reno Rd. N.E. Louisville (off Rt 66 + 44)

CONSTRUCTION DETAILS


BAILING OR PUMPING TEST

Casing diameter 4" Length of casing 27' Pumping rate 20 G.P.M. Duration of test hrs.
 Type of screen none Length of screen Drawdown ft. Date
 Type of pump Shallow Developed capacity
 Capacity of pump Static level—depth to water 4 ft.
 Depth of pump setting 20 Pump installed by
 Date of completion 6-18-62

WELL LOG

SKETCH SHOWING LOCATION

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>sand & Gravel</u>	0 Feet	<u>15</u> Ft.
<u>Gray Slate</u>	<u>15</u>	<u>25</u>
<u>Gravel</u>	<u>25</u>	<u>27</u>
<u>Water at 27'</u>		

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.Drilling Firm Shamp Long
Address 6202-15th N.E.
E. CantonDate 6-23-62
Signed Gene Long