

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER.
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio

No. 273793

County Montgomery Township Madison Section of Township 18
Owner Thomas Dillman Address Dayton Ohio
Location of property 500 foot east of Diamond Mill Road on Wolf Creek Rd north side. 10/81

CONSTRUCTION DETAILS

Casing diameter 6 Length of casing 27 feet
Type of screen Length of screen
Type of pump
Capacity of pump
Depth of pump setting
Date of completion

BAILING OR PUMPING TEST


Pumping rate 14 G.P.M. Duration of test 24 hrs.
Drawdown 30 ft. Date June 17-69
Developed capacity 800 per hr
Static level—depth to water 26 feet ft.
Pump installed by

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>clay</u> <u>Limestone</u>	<u>0 Feet</u> <u>7</u>	<u>7 Ft.</u> <u>60</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm M. L. Shank
Address 2352 N. Union Rd

Date June 17-69
Signed M. L. Shank
Jip 45426

B