

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus 12, Ohio

Nº 276693

County Perry Township Reading Section of Township 5
Owner Chester Beard Address Somerset
Location of property 1 1/4 Miles Northwest of Somerset on S.R. 13
1/4 NW of Somerset on SR 13

CONSTRUCTION DETAILS

Casing diameter 10 Length of casing 23
Type of screen None Length of screen
Type of pump
Capacity of pump
Depth of pump setting
Date of completion

BAILING OR PUMPING TEST


Pumping Rate 20 G.P.M. Duration of test 4 hrs.
Drawdown 10 ft. Date July 16-65
Static level-depth to water 24 ft.
Quality (clear, cloudy, taste, odor)
Pump installed by

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
Soil	0 Feet	1 Ft.
Yellow clay	0	16
Sandy clay	16	30
Gray clay Shale	30	70
Blue clay Shale	70	80
Water @ 32		

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



Drilling Firm M.O. Melick
Address Somerset 1496

Date 7-16-65
Signed M.O. Melick

100