

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus 12, Ohio

Nº 286742

County Auglaize Township Washington Section of Township 21
Owner Mr. Levern Rodheffer Address New Knoxville R. 1 Ohio
Location of property 2 mile north of New Knoxville and 1/2 mile north east on Bay St. Road

CONSTRUCTION DETAILS

Casing diameter 4 1/4 Length of casing 53 ft
Type of screen Length of screen
Type of pump
Capacity of pump
Depth of pump setting 60 ft
Date of completion Aug 6 1965

BAILING OR PUMPING TEST


Pumping Rate 18 G.P.M. Duration of test 2 hrs.
Drawdown 28 ft. Date Aug 6 1965
Static level-depth to water 23 ft.
Quality (clear, cloudy, taste, odor) Cloudy
Pump installed by M. K. Supply Co

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
Yellow Mud	0 Feet	20 Ft.
Blue "	20	40
Cement Gravel	40	50
Gravel	50	53 ft.
Lime Stone	53	94 ft.

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm H. J. Kuder
Address New Knoxville Ohio

Date Aug 6 1965
Signed Levern Rodheffer

30 DATE