

WELL LOG AND DRILLING REPORT

Platner

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus 12, Ohio

Nº 286744

County Auglaize Township St Marys Section of Township 25

Owner Paul Prauter Address New Bremen Ohio

Location of property 2 Mile West + 1/2 mile South of New Knoxville

CONSTRUCTION DETAILS

Casing diameter 4 1/4 Length of casing 90 ft
Type of screen Length of screen
Type of pump
Capacity of pump
Depth of pump setting 75 ft
Date of completion Oct 1 1965

BAILING OR PUMPING TEST

Pumping Rate 18 G.P.M. Duration of test 3 hrs.
Drawdown 710 ft. Date Oct 1 1965
Static level-depth to water 31 ft ft.
Quality (clear, cloudy, taste, odor) Clear
Pump installed by

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
Yellow Clay	0 Feet	20 Ft.
Blue "	20	60
Red Mud	60	90
Lima Stone	90	136

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.
902
90
812
W. Rant 219 E.
Platner Rd
S.

See reverse side for instructions

Drilling Firm J & Kuch

Date Oct 1 1965

Address New Knoxville Ohio

Signed Paul Prauter

Platner Rd

