

WELL LOG AND DRILLING REPORT

DNR 7802.05e

Ohio Department of Natural Resources
Division of Geological Survey, 2045 Morse Road, Columbus, Ohio 43229-6605
Phone (614) 265-6576

Well Log Number

3001957Page 1 of 2 for this record.


WELL LOCATION	CONSTRUCTION DETAILS																																																												
County <u>STARK</u> Township <u>CANTON</u>	Drilling Method: <u>MUD/AIR ROTARY</u>																																																												
Owner/Builder <u>RJAZ PROPERTIES / YOUNG TRUCKS</u>	BOREHOLE/CASING (Measured from ground surface)																																																												
<u>4171 SW NAVARRE RD</u> Address of Well Location	1 { Borehole Diameter <u>12</u> inches Depth <u>380</u> ft. Casing Diameter <u>8</u> in. Length <u>170</u> ft. Thickness <u>0.322</u> in.																																																												
City <u>CANTON</u> Zip Code +4 <u>44706</u>	2 { Borehole Diameter _____ inches Depth _____ ft. Casing Diameter _____ in. Length _____ ft. Thickness _____ in.																																																												
Permit No. <u>OH7677652</u> Section; _____ and/or Lot No. _____	Casing Height Above Ground <u>2</u> ft.																																																												
Use of Well <u>COMMERCIAL</u>	Type { 1: <u>STEEL</u> 2: _____																																																												
Coordinates of Well (Use only one of the below coordinate systems)	Joints { 1: <u>COUPLED</u> 2: _____																																																												
Latitude, Longitude Coordinates	SCREEN																																																												
Latitude: <u>40.77739</u> Longitude: <u>-81.426426</u>	Diameter _____ in. Slot Size _____ in. Screen Length _____ ft.																																																												
Elevation of Well in feet: <u>1082.7</u> +/- _____ ft.	Type _____ Material _____																																																												
Datum Plane: ☐ NAD27 ☐ NAD83 Elevation Source <u>DIGITAL MAP</u>	Set Between _____ ft. and _____ ft.																																																												
Source of Coordinates: <u>DIGITAL MAP</u>	GRAVEL PACK (Filter Pack)																																																												
Well location written description:	Material/Size _____ Vol/Wt. Used _____																																																												
	Method of Installation _____																																																												
	Depth: Placed From: _____ ft. To: _____ ft.																																																												
	GROUT																																																												
	Material <u>BENTONITE SLURRY</u> Vol/Wt. Used <u>2,300</u>																																																												
	Method of Installation <u>PUMPED WITH TREMIE PIPE</u>																																																												
	Depth: Placed From: <u>8</u> ft. To: <u>170</u> ft.																																																												
	DRILLING LOG*																																																												
Comments on water quality/quantity and well construction:	FORMATIONS INCLUDE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.																																																												
	<table border="1" style="width:100%; border-collapse: collapse;"><thead><tr><th>Color</th><th>Texture</th><th>Formation</th><th>From</th><th>To</th></tr></thead><tbody><tr><td>BROWN</td><td>CLAYEY</td><td>CLAY</td><td>0</td><td>6</td></tr><tr><td>BROWN-GRAY</td><td>MEDIUM</td><td>SAND & GRAVEL</td><td>6</td><td>54</td></tr><tr><td>BROWN-GRAY</td><td>SANDY</td><td>SAND</td><td>54</td><td>80</td></tr><tr><td>BROWN-GRAY</td><td>MEDIUM</td><td>SAND & GRAVEL</td><td>80</td><td>108</td></tr><tr><td>GRAY</td><td>SANDY</td><td>SAND</td><td>108</td><td>135</td></tr><tr><td>GRAY</td><td>CLAYEY</td><td>CLAY</td><td>135</td><td>142</td></tr><tr><td>GRAY</td><td>CONGLOMERITIC</td><td>SANDSTONE</td><td>142</td><td>188</td></tr><tr><td>GRAY</td><td>SHALEY</td><td>SHALE</td><td>188</td><td>300</td></tr><tr><td>GRAY</td><td>CONGLOMERITIC</td><td>SANDSTONE</td><td>300</td><td>335</td></tr><tr><td>WHITE</td><td>CLEAN</td><td>SANDSTONE</td><td>335</td><td>380</td></tr><tr><td></td><td></td><td>WATER AT</td><td>57</td><td>380</td></tr></tbody></table>	Color	Texture	Formation	From	To	BROWN	CLAYEY	CLAY	0	6	BROWN-GRAY	MEDIUM	SAND & GRAVEL	6	54	BROWN-GRAY	SANDY	SAND	54	80	BROWN-GRAY	MEDIUM	SAND & GRAVEL	80	108	GRAY	SANDY	SAND	108	135	GRAY	CLAYEY	CLAY	135	142	GRAY	CONGLOMERITIC	SANDSTONE	142	188	GRAY	SHALEY	SHALE	188	300	GRAY	CONGLOMERITIC	SANDSTONE	300	335	WHITE	CLEAN	SANDSTONE	335	380			WATER AT	57	380
Color	Texture	Formation	From	To																																																									
BROWN	CLAYEY	CLAY	0	6																																																									
BROWN-GRAY	MEDIUM	SAND & GRAVEL	6	54																																																									
BROWN-GRAY	SANDY	SAND	54	80																																																									
BROWN-GRAY	MEDIUM	SAND & GRAVEL	80	108																																																									
GRAY	SANDY	SAND	108	135																																																									
GRAY	CLAYEY	CLAY	135	142																																																									
GRAY	CONGLOMERITIC	SANDSTONE	142	188																																																									
GRAY	SHALEY	SHALE	188	300																																																									
GRAY	CONGLOMERITIC	SANDSTONE	300	335																																																									
WHITE	CLEAN	SANDSTONE	335	380																																																									
		WATER AT	57	380																																																									
WELL TEST *																																																													
Pre-Pumping Static Level <u>67.8</u> ft. Date <u>12/11/2021</u>																																																													
Measured from <u>TOP OF CASING</u>																																																													
Pumping test method <u>PUMPING</u>																																																													
Test Rate <u>224</u> gpm Duration of Test <u>24</u> hrs.																																																													
Feet of Drawdown <u>40.3</u> ft. Sustainable Yield <u>224</u> gpm																																																													
*(Attach a copy of the pumping test record, per section 1521.05, ORC)																																																													
Is Copy Attached? ☐ Yes ☒ No	Flowing Well? ☐ Yes ☒ No																																																												
PUMP/PITLESS																																																													
Type of pump _____ Capacity <u>0</u> gpm																																																													
Pump set at <u>0</u> ft. Pitless Type _____																																																													
Pump installed by _____																																																													
I hereby certify the information given is accurate and correct to the best of my knowledge.																																																													
Drilling Firm <u>NATIONAL WATER SERVICES (LANC)</u>																																																													
Address <u>281 HAMBURG RD</u>																																																													
City, State, Zip <u>LANCASTER OH 43130</u>																																																													
Signed <u>BOB HARDIN</u> Date <u>7/18/2022</u>																																																													
(Filed Electronically)																																																													
ODH Registration Number <u>003807</u>	Last Revised on <u>7/1/2025</u>																																																												
Aquifer Type (Formation producing the most water.) <u>SANDSTONE</u>																																																													
Date of Well Completion <u>12/11/2021</u> Total Depth of Well <u>380</u> ft.																																																													

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
Distribute copies of this record to Customer, and Local Health Department.

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 2045 Morse Road, Columbus, Ohio 43229-6605
Voice (614) 265-6740 Fax (614) 265-6767

Well Log Number

3001957Page 2 of 2 for this record.

String: 1

Borehole Depth: 380 ft.

Borehole Diameter: 12 in.

Casing Length: 170 ft.

Casing Diameter: 8 in.

| Borehole

| Casing

| Grout

| Water At

Some formations labels
have been removed due
to space limitations.