

WEI LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus 12, Ohio

31
OK
No 300201

County London Township Jerome Section of Township
Owner Jim Priddy Address Plain City RFD
Location of property Subs Home Rd and driveway

CONSTRUCTION DETAILS		BAILING OR PUMPING TEST	
Casing diameter <u>4 1/4</u>	Length of casing <u>16</u>	Pumping Rate <u>10</u> G.P.M.	Duration of test <u> </u> hrs.
Type of screen <u> </u>	Length of screen <u> </u>	Drawdown <u>none</u> ft.	Date <u>July 10-63</u>
Type of pump <u> </u>		Static level-depth to water <u> </u> ft.	
Capacity of pump <u> </u>		Quality (clear, cloudy, taste, odor) <u>clear</u>	
Depth of pump setting <u> </u>		<u>Tested by Bailing</u>	
Date of completion <u>July 10-63</u>		Pump installed by <u> </u>	

WELL LOG			SKETCH SHOWING LOCATION	
Formations Sandstone, shale, limestone, gravel and clay	From	To	Locate in reference to numbered State Highways, St. Intersections, County roads, etc.	
<u>Clay</u>	<u>0 Feet</u>	<u>16 Ft.</u>	N. W. <u>well</u> E. <u>Carry Rd</u> S.	
<u>Limestone</u>	<u>16</u>	<u>36</u>		

See reverse side for instructions

Drilling Firm Walter Plummer Date July 10-63
Address Paul Rd RFD Signed Walter Plummer LOCATED