

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus 12, Ohio

NO 302332

County Paraguay Township Atwater Section of Township Center
Owner W. H. Oplinger Address 1370 St Rt 183
Location of property same

CONSTRUCTION DETAILS	BAILING OR PUMPING TEST
Casing diameter <u>6"</u> Length of casing <u>64</u>	Pumping Rate <u>10</u> G.P.M. Duration of test <u>1</u> hrs.
Type of screen <u> </u> Length of screen <u> </u>	Drawdown <u>25</u> ft. Date <u>June 10 - 64</u>
Type of pump <u> </u>	Static level-depth to water <u>12</u> ft.
Capacity of pump <u> </u>	Quality (clear, <u>cloudy</u> , taste, odor) <u> </u>
Depth of pump setting <u>50</u>	Pump installed by <u> </u>
Date of completion <u> </u>	

WELL LOG			SKETCH SHOWING LOCATION
Formations Sandstone, shale, limestone, gravel and clay	From	To	Locate in reference to numbered State Highways, St. Intersections, County roads, etc.
<u>CLAY</u>	0 Feet	<u>12</u> Ft.	<u>N.</u>
<u>CLAY & SAND</u>	<u>18</u>	<u>41</u>	
<u>GRAVEL & SAND</u> <u>WATER</u>	<u>41</u>	<u>60</u>	<u>W.</u> <u>E.</u> <u>224</u> <u>Rt 183</u> <u>S.</u>

See reverse side for instructions

Drilling Firm Buckeye Drilling
293 S. 8th St. Dayton, Ohio
Address Deerfield Ohio

Date June 10 - 64
Signed Osley Scott
51
LOCATED