

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus 12, Ohio

No. 302345

County Portage Township Deerfield Section of Township 9392
Owner Alfred W. Jones Address 9392 Yale Rd
Location of property Yale Rd. Diamond Ohio

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 60
Type of screen 4" Length of screen 178
Type of pump —
Capacity of pump —
Depth of pump setting 100
Date of completion —

BAILING OR PUMPING TEST


Pumping Rate 10 G.P.M. Duration of test 1 hrs.
Drawdown 64 ft. Date 9-18-64
Static level-depth to water 56' ft.
Quality (clear, cloudy, taste, odor) —
Pump installed by —

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
CLAY	0 Feet	46 Ft.
CLAY + SAND	46	59
SHALE	59	122
GRAYSTONE WATER	122	162
SHALE	162	185
INTUN SAND WATER	185	210

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm Buckeye Drilling Date 9-18-64
Address Deerfield Ohio Signed Casper Scott Jr.