

WEI LOG AND DRILLING REPORT

ORIGINAL

State of Ohio

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

DEPARTMENT OF NATURAL RESOURCES

Division of Water
1562 W. First Avenue
Columbus 12, Ohio

No 302915

County Windsor Township Dymoochee Section of Township 30
Owner Alvin Lawrence Address R.R. 4 Upper Sandusky Ohio
Location of property 107 North of Upper Sandusky west of Rt 53

CONSTRUCTION DETAILS

Casing diameter 4 1/4 Length of casing 43 ft.
Type of screen Length of screen
Type of pump Submersible
Capacity of pump 9 gal per min
Depth of pump setting 43 ft.
Date of completion Jan. 5, 1964

BAILING OR PUMPING TEST


Pumping Rate 2 1/2 G.P.M. Duration of test 1 hrs.
Drawdown 2 ft. Date Jan 6, 1964
Static level-depth to water 20 ft.
Quality (clear, cloudy, taste, odor) Clear
Pump installed by Morris Lawrence

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Yellow Clay</u>	<u>0 Feet</u>	<u>25 Ft.</u>
<u>Blue Clay</u>	<u>25</u>	<u>42 ft.</u>
<u>sand.</u>	<u>42 ft.</u>	<u>43 ft.</u>
<u>Lime Stone</u>	<u>43</u>	<u>45 ft.</u>
<u>Water</u>	<u>44 ft.</u>	

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm R.O. Pittman

Address R.R. 4 Upper Sandusky Ohio

Date Jan. 6, 1964

Signed Morris O. Lawrence

129
1966-129 C3