

WELL LOG AND DRILLING REPORT

ORIGINAL

1032 ✓

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus 12, Ohio

No 303667

County Frank Township Green Section of Township 24
Owner Russell Casner Address Springfield RFD
Location of property 5 mi S. of Springfield on Pelham Place

CONSTRUCTION DETAILS

Casing diameter 6 Length of casing 69 ft
Type of screen none Length of screen 1
Type of pump none yet
Capacity of pump
Depth of pump setting
Date of completion Dec 18 1968

BAILING OR PUMPING TEST


Pumping Rate 13 G.P.M. Duration of test 3 hrs.
Drawdown 10 ft. Date
Static level-depth to water 20 ft.
Quality (clear, cloudy, taste, odor)
Pump installed by owner

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
started in an old open well.	0 Feet	10 Ft.
Gravel	10	13
Clay	13	27
Gravel	27	33
Clay	33	50
Gravel	50	57
Clay	57	67
Sand	67	69

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm W. L. Parker Date Dec 18 1968

Address Springfield 4818 Twyke Signed W. L. Parker

43502

7. Parker Driller 18