

WEI LOG AND DRILLING REPORT

LOCATED

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus 12, Ohio

No 303864

County Fairfield Township Liberty Section of Township 5
Owner Ray Roshon Address Box 303 Adena Ohio
Location of property intersection of St Rt 204 + Refugee Rd - South side

CONSTRUCTION DETAILS

Casing diameter 5 Length of casing 44
Type of screen perforation Length of screen 3
Type of pump
Capacity of pump
Depth of pump setting
Date of completion

BAILING OR PUMPING TEST


Pumping Rate 20 G.P.M. Duration of test 2 hrs.
Drawdown -0- ft. Date June 16-1964
Static level-depth to water 32 ft.
Quality (clear, cloudy, taste, odor) clear
Pump installed by

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>yellow & stone clay</u>	0 Feet	<u>14</u> Ft.
<u>gray stone clay</u>	<u>14</u>	<u>35</u>
<u>Boulders & water</u>	<u>35</u>	<u>44</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm George C Blum
Address Baltimore, Ohio

Date Aug 10, 1964
Signed George C Blum

55