

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus 12, Ohio

No 304156

County LUCAS Township SYLVANIA Section of Township 9
Owner FRED NUGENT Address 2965 HASTY RD
Location of property BRINT & KING RD

CONSTRUCTION DETAILS

Casing diameter 4 1/4 Length of casing 47'
Type of screen - Length of screen -
Type of pump SUBMERGE
Capacity of pump 900 G.P.H.
Depth of pump setting 55
Date of completion 4/11/64

BAILING OR PUMPING TEST


Pumping Rate 20+ G.P.M. Duration of test 2 hrs.
Drawdown 4 ft. Date 4/11/64
Static level-depth to water 35 ft.
Quality (clear, cloudy, taste, odor) Good - clear
Pump installed by C.H. Bond

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>SAND</u>	<u>0 Feet</u>	<u>12 Ft.</u>
<u>CLAY</u>	<u>12</u>	<u>30</u>
<u>CLAY & GRAVEL</u>	<u>30</u>	<u>38</u>
<u>LIMESTONE</u>	<u>38</u>	<u>63</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm C.H. BOND
Address 3034 Wilford Rd
TOLEDO OHIO

Date 4/11/64
Signed C.H. Bond