139

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus 12, Ohio

№ 306146

County COLUMBIANA Township YELLOW CREEK Section of Township 12.

Owner JOHN PICKERING Address PARSHALL ST.

Location of property PARSHALL ST. HILLCREST WELLSVILLE

CONSTRUCTION DETAILS

Casing diameter 6½ Length of casing 32' 6"

Type of screen Length of screen

Type of pump SUBMERSIBLE

Capacity of pump 5 G. P. M.

Depth of pump setting 280 FT.

Date of completion

BAILING OR PUMPING TEST

Pumping Rate G.P.M. Duration of test hrs.

Drawdown ft. Date

Static level-depth to water 180 ft.

Quality (clear, cloudy, taste, odor)

BAILER TEST 1. G. P. M.

Pump installed by O. E. MILLER

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
CLAY	0 Feet	17 Ft.
BLACK ROCK	17	28
SHALE	28	68
SLATE	68	85
WHITE SAND ROCK	85	87
CLAY	87	93
GREY SAND ROCK	93	143
Black SLATE	143	159
SAND ROCK	159	177
SLATE	177	194
WHITE SAND ROCK	194	262
COAL	262	264
BLACK SAND ROCK	264	265
GREY SAND ROCK	265	302

WATER
220 TO 225

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm O. E. MILLER DRILLING Date DEC. 21, 1966

Address P. O. BOX 78, E. L. O. Signed O. E. MILLER

LOCATED

48-B