

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus 12, Ohio

No 306879

County Lorain Township Brownhelm Section of Township South West

Owner Wesley Martin Address Rt 113 E. Ambient

Location of property 4th House on Right Middle Ridge

CONSTRUCTION DETAILS

Casing diameter 6 Length of casing 51 1/2
Type of screen Deep well Length of screen 76
Type of pump 115 GPM
Capacity of pump 76
Depth of pump setting Aug 9-1967
Date of completion Aug 9-1967

BAILING OR PUMPING TEST

Pumping Rate 3 G.P.M. Duration of test 8 hrs.
Drawdown 7.5 ft. Date Aug 9/67
Static level-depth to water 24' ft.
Quality (clear, cloudy, taste, odor) Clear
Pump installed by Owner

WELL LOG

Formations Sandstone, shale, limestone, & gravel and clay	From	To
<u>Sand</u>	<u>0 Feet</u>	<u>20 Ft.</u>
<u>Clay & sand</u>	<u>20</u>	<u>31</u>
<u>Gravel</u>	<u>31</u>	<u>56'</u>
<u>Shale Gray</u>	<u>56</u>	<u>82'</u>
<u>Water at 62'</u>		

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

4th Middle Ridge
House on Right
Brownhelm Rd.
W. 113
Rt 113 Elyria
S. E.

See reverse side for instructions

Drilling Firm J. Garrison
Address Rt 2 Elyria

Date Aug 9 / 67
Signed J. Garrison