

WE LOG AND DRILLING REPORT SUMNERLAND RD ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus 12, Ohio

No 308833

County Allen Township Amanda Section of Township 2
Owner Chuck Powell Address 139 E Euclid St Lima
Location of property 400' So of Agater rd on Sumnerland Rd.

CONSTRUCTION DETAILS

Casing diameter 4 1/4 Length of casing 34 1/2
Type of screen Length of screen
Type of pump
Capacity of pump
Depth of pump setting
Date of completion 11-24-64

BAILING OR PUMPING TEST


Pumping Rate 12 G.P.M. Duration of test 1 hrs.
Drawdown 2 ft. Date 11-24-64
Static level-depth to water 22 ft.
Quality (clear, cloudy, taste, odor) Clear
Pump installed by

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
	0 Feet	Ft.
<u>Clay</u>	<u>0</u>	<u>30</u>
<u>Clay + gravel</u>	<u>30</u>	<u>33</u>
<u>Sand + gravel</u>	<u>33</u>	<u>34 1/2</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm Robert H. Lehman Date 11-24-64
Address 2955 Shawnee Rd Lima Signed Robert H. Lehman

LOCATED