

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus 12, Ohio

198
No 308834

County Allen Township Amanda Section of Township 15
Owner Tom Jones Address RR #2 Spencerville
Location of property 1/2 mi S of SR 117 on SR 198

CONSTRUCTION DETAILS

Casing diameter 4 1/4 Length of casing 44
Type of screen..... Length of screen.....
Type of pump.....
Capacity of pump.....
Depth of pump setting.....
Date of completion 12-14-64

BAILING OR PUMPING TEST


Pumping Rate 10 G.P.M. Duration of test 1 hrs.
Drawdown 20 ft. Date 12-14-64
Static level-depth to water 40 ft.
Quality (clear, cloudy, taste, odor) Slight Sulfur
Pump installed by.....

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
	0 Feet	Ft.
<u>Clay</u>	<u>0</u>	<u>36</u>
<u>Clay & gravel</u>	<u>36</u>	<u>44</u>
<u>Limestone</u>	<u>44</u>	<u>115</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



S.

See reverse side for instructions