

WELL LOG AND DRILLING REPORT

#58

ORIGINAL

State of Ohio

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

DEPARTMENT OF NATURAL RESOURCES

Division of Water
1562 W. First Avenue
Columbus 12, Ohio

No 310467

County Wayne Township Congress Section of Township 1

Owner Harold Pentkew Address R.D. #2 West Salem

Location of property 1/2 mi. N. of West Salem on C.R.D. 88 then W. 1/2 mi. on Twp. Rd. 70 - State

CONSTRUCTION DETAILS

Casing diameter 6 5/8" 10' Length of casing 67 1/2'
Type of screen none Length of screen
Type of pump 1/2 H.P. Jet
Capacity of pump 600 G.P.M.
Depth of pump setting 25'
Date of completion

BAILING OR PUMPING TEST

Pumping Rate 10 G.P.M. Duration of test 24 hrs.
Drawdown 17 1/2 ft. Date 8-21-65
Static level-depth to water 17 ft.
Quality (clear, cloudy, taste, odor) clear
Pump installed by

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Clay</u>	0 Feet	<u>35</u> Ft.
<u>Coarse Gravel</u>	35	38
<u>Clay & Gravel</u>	38	67
<u>Sand & Gravel</u>	67	70
<u>Water 67'</u>		

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

